

#### Thermoline Ltd.

47 Tzela Hahar st., Modiin, Israel Tel: 02-679-94-79

Tel: 02-679-94-79 Tel: 03-550-45-27

www.thermoline.co.il/control

# **XR130D**

# Digital controller for N.T. with "off cycle" defrost, additional configurable re

D: 4 DIN Rail mounting

			-					
_	$\overline{}$		•	т	ш	м.	$\overline{}$	e
	_	а	ш	ш.	41	ш	_	

s, d.p., -
30Vac

## **Probe inputs**

Thermostat	NTC / PTC
Display	NTC / PTC

### **Digital inputs**

Start defrost, pressure switch, energy saving, AUX, generic alarm serious alarm mode	configurable
Door switch	present

## **Relay outputs**

Compressor	8A	
Alarm	16A	

# **Other Outputs**

Hot Key/Prog Tool Kit output	present
Serial output	RS485

## **Other**

Buzzer	present	

# Measurement

Measurement range	probe dependent
Accuracy	Better than 1% of full scale

#### **Generals**

Housing	Self extinguishing ABS
Display type	red LED (13.2mm high)
Data Storage	EEPROM memory
Operating temperature	0°÷60°C 32°÷140°F
Storage temperature	-30°÷85°C





#### Thermoline Ltd.

47 Tzela Hahar st., Modiin, Israel Tel: 02-679-94-79 Tel: 03-550-45-27

www.thermoline.co.il/control

#### 22°÷185°F

Relative humidity	20÷85%
Resolution	0.1°C or 1°F
Connection	Screw-terminal block <2.5mm²